



Utilities  
Wastewater Compliance  
3525 Lena Road  
Bradenton, FL 34211  
Phone: (941) 792-8811, ext. 5180  
[www.mymanatee.org/utilities](http://www.mymanatee.org/utilities)

### Local Limits

No person shall discharge wastewater containing pollutants in excess of the following instantaneous maximum allowable discharge limits:

**2.51 mg/L Arsenic**  
**7290 mg/L cBOD5**  
**287 mg/L Chloride**  
**0.73 mg/L Cadmium**  
**9.90 mg/L Chromium**  
**28.48 mg/L Copper**  
**4.70 mg/L Cyanide**  
**1.87 mg/L Lead**  
**0.38 mg/L Mercury**  
**1.26 mg/L Molybdenum**  
**11.08 mg/L Nickel**  
**2.11 mg/L Selenium**  
**16.06 mg/L Silver**  
**1830 mg/L Total Suspended Solids**  
**4.78 mg/L Zinc**

The above limits apply at the point where the wastewater is discharged to Manatee County's sanitary sewer collection system. All concentrations for metallic substances are for "total" metals unless indicated otherwise. The Director may impose limitations in addition to, or in place of, the concentration-based limitations above.